...EMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
...SION OF ENVIRONMENTAL HEALTH
...SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

...WNER: Don Winbish
ADDRESS:
APPLICANT:
APPLICATION DATE:
DATE EVALUATED: 8-2-97
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360 gpd
PROPERTY SIZE: ~ 75 ac
LOCATION OF SITE: Lot 1 D. Winbish
PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
...LUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
...YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8%	0-17	SAB R C	fi sp SO					PS .3
		17-48	w weak sab R C L	fi to sp sbp					
2	L 4%	0-13	SAB loam C/ CL	fi to sp-SSP					PS .3
		13-48	w weak sab R C L	fr to SSP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: