DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ORT
APPLICANT: Danny Fisher
ADDRESS: _____
APPLICATION DATE: _____
DATE EVALUATED: 2-28
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 450gpd
PROPERTY SIZE: .6 Ac
LOCATION OF SITE: Lot 18 Sect 1 Hawthorne Hill
PROPERTY RECORDED: ES
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4-6%	0-8	R bench	fr					.3
		8-15	sab rc	fi sp I-II					
		15-45	msab R many cl	fr					
			few gravel						
			few fine roots						
2	L 4-6%	0-6	Bench	fr					.3
		6-14	sab rc	fi sp I-II					
		14-29	msab R many cl	fr-vfr many mangan concretions					
		29-48	wksab R cl	fr-fi sp I					
			few gravel few fine roots						
3	L 4-6%	0-8	R-bench	fr					.3
		8-20	sab rc	fi sp II					
		20-48	m-wk sab rcl	fi-fr I-II					
			few gravel few fine roots						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____