IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. G Curlee DATE 10-7-99 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 TL on 1452 ½ mi on left

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 35 SECTION OR BLOCK NO. 14


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 3/4 ac

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/1 inch
Topography 12% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by F.J. Ervin

IMPROVEMENTS PERMIT BY J C Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-8-99

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold