4638827123

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sandy Clark DATE 9-2-05 PERMIT NO. 209

PHONE: Business _____ Home 492-7441

LOCATION NC 150 W TR on 1303 Lefno water TR on 1479 1mi on left S. R. No. 1417

SUBDIVISION NAME Lake Norman LOT NO. 20 SECTION OR BLOCK NO. 11


House ( ) Mobile Home ( ) Business ( ) Other Double wide mobile Home

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area over ½ acre

Character & Porosity of Soil Fine Sandy Clay loam Perosity Fair
Percolation Rate Not taken
Topography 2% Slope on line
Depth to Water Table 10'+
Rock or other impervious formations None

492-7441



Plot of System 1479 Road

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold