IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR [redacted] Sandy Cleary DATE 12-17-75 PERMIT NO. 276

PHONE: Business _____ Home [redacted] 492-7441

LOCATION 150 West TR on 1303 [redacted] TR on 1479 1½ mi on left S. R. No. [redacted]1497

SUBDIVISION NAME Lake Norman LOT NO. [redacted]20 SECTION OR BLOCK NO. [redacted]4

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ½ acre


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Not taken

Topography 3 to 4% slope on line

Depth to Water Table 10'+

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Rowan Septic Tank

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-17-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold