IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 16578 7 PIN # 4638858857 DATE MAY 3, 2012

OWNER RANDOLPH MILLWOOD APPLICANT: BUILTRITE PHONE: Home/Cell # 704-201-9935 Business #

SITE ADDRESS 124 SAGEMORE RD MOORESVILLE NC OWNER / APPLICANT ADDRESS 132 ASSEMBLY DR.

SITE DIRECTIONS PERTH RD NORTH - TR SAGEMORE - ON RIGHT

SUBDIVISION CL+J BLOCK / SECTION 14 LOT # 23 LOT AREA 1.1 AC DESIGN FLOW 360 GPD L.T.A.R. .25 GPD/FT2

Septic Tank 1000 Gallons: STB 760 Date 12-27

Pump Tank 1000 Gallons: P T 0363 Date 11-17

Pump Make GOULDS Model WE0311M Serial # 43MP

No. Nitrification Fields: 1 No. Lines 4 Linear Feet 240

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required ☒ YES ☐ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons 6

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

INITIAL SITE SKETCH

1"=50'

SAGEMORE ROAD

REPAIR

113'

12' 60'

15 64'

15 62'

12 54'

55 PANELS INSTALLED

CHECKED TANKS LINES PRESSURE 5-18-12 BA

CHECKED ELECT

DRY WELL

REPAIR

263'

VALVE BOX

AS BUILT SKETCH

194'

PT ST

36'

84'

43'

92'

42'

72'

EXISTING BUILDING

WELL AREA

225'

211'

ITT Engineered for life

GOULDS PUMPS

WE0311M

SUBMERSIBLE PUMP

1/3HP 1/60/115 5.38" 10.7MA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.*

☒ ***IMPROVEMENT PERMIT*** *with plat valid ~~without expiration.~~ site plan valid 60 mo.*

☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date 5/4/12

IMPROVEMENT PERMIT by: C. Blackburn REHS Date 5/3/12

AUTHORIZATION TO CONSTRUCT by: C. Blackburn REHS Date 5/3/12

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

Installed by: A-1 BACKHOE

OPERATION PERMIT by: REHS REHS Date

Existing System Inspected by: REHS Date

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant