DEPARTMENT OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Danny Fisher APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: .62 ac
LOCATION OF SITE: Lot 6 Sec I Hackberry PROPERTY RECORDED: no
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4-6%	0-20	sab r-brn cl	fr					.3
		20-32	sab R heavy cl	fr					
		32-	m-wk sab R cl	fi-fr					
			Some sc. Rock few yellow mottles						
2	L 4-6%	0-5	r brn cl	fr					.3
		5-27	sab R heavy cl/light c	fr					
		27-48+	m-wk sab R cl	fi-fr					
			few yellow mottles						
3	L 4-6%	0-6	sab R-brn cl	fr					.3
		6-14	sab R light c/heavy cl	fi-fr					
		14-48	m-wk sab R cl	fi-fr					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____