DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Denny Fisher APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: 1.54ac
LOCATION OF SITE: Lot 3 Sect I, Hawberries Hideaway Cove PROPERTY RECORDED: no
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

NEED more pits

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2-4%	0-6	brwn cl	1:1 fr					.3
		6-17	sabr rc	1:1 fi sp					
		17-43	wk sab g-r cl	1:1 fi ss, sp					
			gray mottles of few brt gyr						
2	L 2%	0-10	SSAB R heavy cl/ Light	fr ss, sp					
		10-20	MSAB R cl	fi ss, sp					
		20-48	wk sab g-r cl	fi					
			many brts gyr						
			few to many manganese nodules						
3	L 2-4%	0-5	BRN CL	fr					.3
		5-13	SSAB RC	1:1 fi sp					
		13-23	MSSAB R CL	1:1 fi-fr					
		23+	wk SAB R CL	1:1 fi-vfi					
4	L 4-6% APH 3-1/96	0-9	msab R brn cl	1:1 fr ss sp 1:1					.3+
		9-17	SSAB R heavy cl	1:1 fi sp 1:1					
		17-44	m-wk sab r cl	1:1 fr 1:1					
		44-48+	g-wk sab fsl sap	1:1 fr 1:1					
			many gallic mottles						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___