DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jimmy Tucker APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2-27-96
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 420 PROPERTY SIZE: .63 Ac
LOCATION OF SITE: Lot 1, Sect I Hawkeview corner of Loch & Hollow PROPERTY RECORDED: no
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed ~~Need more info~~ KEEP Shallow trenches

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L-F ~4%	0-16	SAB R heavy cl	1:1 fi sp					
		16-48	wk SAB R cL	1:1 fi ss,sp					
			few to many y rdx mottles						
2	T 2%	0-9	SAB R cL	1:1 fr		30"			
		9-30	gr-R scL	1:1 fr					
		30+	tan L SAP/WR	fi-vfi					
3	F-T 0-2%	0-10	SAB R-brn cL	fr					~3
		10-48+	M-wk SAB brn-R scL	fi-fr					
			Many y rdx mottles						
			few bits of wood						
4	CC-D	0-14	SAB brn cL	fr fi	wet stinky				.25-.3
		14-36	SAB d brn heavy cL	fi sp					
		36-48	SAB brn-R c	fi sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____