DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Hampton Creek LLC — APPLICANT: _____
ADDRESS: 10 — APPLICATION DATE: _____ — DATE EVALUATED: 5-29-18
PROPOSED FACILITY: _____ — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 37 Sea Harbor Landing — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-5	compacted fill						PS .3 @ 32"
		5-32	SAB R cl	fr-ss/sp ss/p					
		32-54	wk sbk/pl/k y cl	L ss/p					
2		0-8	SAB loam/scl	fr					LPP .4
		8-26	SAB R cl	fr-ss/sp					
		26-52	wk sbk/pl/k mottled	L ss/p					
3	5% 3-5%	0-28	SAB R cl	fr-ss/sp					LPP .45
		28-64	wk sbk/pl/k mottled	L fr-ss/sp					
			Saprolite bedrock @ 64" +						
4		0-27	wk sbk/pl/k sl cl	fr ss/sp					PS .3
		27-45	SAB R cl	fr ss/sp					
			few silica mottles						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____