DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Stumpy Creek LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-4-98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 46 Sec III Harbor Landing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other 0
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut Ned was pit & near
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-8	gr-sdy clay sch fr						PS .3
		8-30	SAB w/ clay pebs sp sso						
		30-48	wk f sbk w/ pebs fr sso sp						
			fair fore unit sap/fall common						
2		0-4	gr fine sdy sch fr						PS .3
		4-24	SAB RC/CL fr sp so						
		24-48	wk f sbk/mass mx CL fr ss sp so						
			common gravel/rock unit sap						
3		0-3	gr fine sch	fr					PS .3 @ 40
		3-40	SAB RC/CL	fr ss sp so					
		40+	hard gravel/rock - pit stopped						
4	4-6-98	0-6	gr fine sch	fr					PS .3
		6-48	SAB RC/CL	fr ss sp so					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Acc LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____