DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shumaker Creek LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-9-98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 47 Seat Ft Horseshoe Landing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Get sidelot stakes flagged also
Left front corner
Left side PL 22.5

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 27%	0-4"	sl brn sl	fr					PS .3
		4-25"	sl brn scl	fr so-sso sap					
		25-33	wk sbk brn scl	fr sso sap (mostly soil)					
			(Rx) common small faint red mottles	at and just at 25-33"					
2	L 22%	0-7	sbk brn sl	fr					PS .3
		7-25	sbk red cl	fr sp-sso sap					
		25-54	wk sbk - R/BL scl	fr sso sp sap					
			few med fine sap						
3	7-7-98	0-3	gr brn sl	fr					PS .3
		3-43	sbk red cl	fr sp-sso sap					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Stumpy Creek LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-9-98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 48 Sect III Hatteras Landing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☑ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Wet side L's flagged & more soil work

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2%	0-4	gr brn scl	fr		(U)			
		4-16/28	SAB rel/cL	fi sp scep					
		16/28-32	cL/SAP mix	vfi sssp					
		32-60	SL-SAP. w/ few fine/prom/red cL		SAP @ 36" Looks promising				
2		0-3	gr brn SL/scL	fr					
		3-21	SAB rel/cL	fi sp		(U)			
		21-35	cL/SAP mix						
		35-71	SL/L SAP						
3		0-7	gy brn scl	fr					PS .3
		7-43	SAB rel/cL	fi sp-sssp					
			few fine ind SAP /bl zones, pockets						
4	Lot 49	0-3	gr brn scl	fr					PS .3
		3-31	SAB rel/cL	fi sp sssp SAP					
		31-48	wk blk brn cL	fi sssp SAP, fine ind SAP					
			and quartz fragments on one corner of pit						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____