DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9-1-98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 74 Sec 4 Harbor Landing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1		0-4	brn scl	fr					PS .3
		4-20	sa lo rc	fr sp sso					
		20-53	wk eb yrcl	fss sp sso, dk mn lyr/sap					
2		0-5	brn scl						A .3 @ 24"
		5-15	sa lo rc	fr sp sso					
		15-43	mwk eb yrcl	fss sp sso	mn lyr/sap	mottled soil			
		43+	WR/soil mix						
3		0-4	brn scl						PS .3
		4-25	sa lo rc	fr sp sso					
		25-52	wk eb/mb yrcl	fss sp sso					
			dk mn spots, gravel/cobbles						
4		0-15	sa lo rc	fr sp					PS .3 @ 24"
		15-40	wk eb yrcl	fss sp sso					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____