DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Krom APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 1-28-95
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 92 Mill Pond PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	Brwcl	1:1 fr					.3+
		4-22	ssabk RC	1:1 fi, s,p.					
		22-48	mssbk RCL	1:1 fi-fr	s,p-ss+sp				
2		0-3	R-brw cl	1:1 fr					.3+
		3-26	ssabk RC	1:1 fi s,p.					
		26-48	mssbk RCL	1:1 fi-fr s,p					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER ACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER() PRESENT: ___