DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Mike Kwon (Now lot 30) OWNER: ___ AGENT: ___ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 3/22/95
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Eastern side Kit Fox Rd. west to St Rte 302
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LSS	0-8	sa-cL						.3
		8-23	S sa-c						
		23-48	wk sab cL mixed w/ SL and SiCL mottles						
2	LSS 15-25%	0-4	sa-cL	fri					.3
		4-20	sa-c	mfr					
		20-34	wk sab cL	sfr					
		34-65	wk sab cL w/ SiCL mottles	fr					
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: Shallow and gravelly