DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Keown
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
DATE EVALUATED: 9-22-11
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 35, Mills Pond
PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1948 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	LSS ~10%	0-7	ssabk R-brwn L	1:1 fr	NA	NA	NA	NA (-3+)	
		7-48	ssabk RC	1:1 fi sp					
2	LSS 10-15%	0-6	mwksabk brwn L	1:1 fr				-3	
		6-13	mcsabk rbrwn fr/sh	1:1 fr					
		13-36	ssabk RC	1:1 fi sp.					
		36-46	sabk R-brwn heavy sil	1:1 fi					
			few rdx weathers						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___