DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Kemm
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: SFH APPLICATION DATE: ___ DATE EVALUATED: 11-22
LOCATION OF SITE: Lot 18 Millstone PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 6-8%	0-7	R-brwl						
		7-28	SaCl RC	fi FP					
		28-48	m-wksbk brn-R Cl	fi SS MP					.3
			sand y wet @ 38-39"						
2	LSS 3-6%	0-6	m-wksbk R-brwl	fr SS MP					
		6-25	SaCl light RC	fi SS MP					
		25-45	m-wksbk red w/ brn-gray	fr					
		45-48	bedrock R						.3
3		0-12	R-brwl						
		12-30	SaCl R heavy RCL	fi fr SP					
		30-48	m-wksbk red	fr					
			y-wet sand.						.3
4	LSS Near bottom of Lot #38 Lot 17	0-5	R brwl	fr					
		5-19	MSaCl R RCL heavy	fi fr SS MP-SP					
		19-40	wksbk light RCL w/red gray						
		40-47	hard y wet						.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___