DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wesley Kamm
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360 gpd
DATE EVALUATED: 11-27-
LOCATION OF SITE: Lot 18 Whitetail
PROPERTY SIZE: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 6-5%	0-7	R-brwcl						-3
		7-28	Sa br sc	fi sp					
		28-48	m-wk sab br-R cl	fi sp					
			inf y wa @ 25-30"						
2	LSS 6-10%	0-6	m-wk sab R-brwcl	fi sp					-3
		6-25	sab sacl	fi sp					
		25-45	m-wk sab cbl w/ inf wa	fr					
		45-48	hard y wR						
3		0-12	R-brwcl						-3
		12-30	sab R-brwcl	fi-fr sp					
		30-48	m-wk sab cbl	fr					
			y wk inf.						
4	LSS Broadmoor 25' Lot 77	0-5	R brwcl	fr					-3
		5-19	m sab R cbl	fi fr sp					
		19-46	wk sab hard cbl w/ inf y wR						
		46-47	hard y wR						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____