4638902631

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry Childress DATE 2-25-76 PERMIT NO. 38

PHONE: Business _____ Home 873-3384

LOCATION 1504 TR on 1303 TR on 1479 Last Lan on left S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 4 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 40 Faster
Topography 7 2 to 6 Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1,500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 250 Linear Ft. 333
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lake Septic Tank

ICHD-Environmental Health Division
The proposed / existing Addition over Deck addition does not appear to impact the existing septic system.
**NOTE: _____

Andy Melville R.S.
Date: 3-2-12

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 2-25-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold