IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry Childress DATE 2-25-76 PERMIT NO. 38

PHONE: Business _____ Home 873-3584


LOCATION 150w TR on 1303 TR on 1479 Last Lan on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 4 SECTION OR BLOCK NO. 4

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 60 min/in
Topography 7 2 % Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 250 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tanks

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hamilton DATE 2-25-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold