DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Barry Ervin
ADDRESS: _____
PROPOSED FACILITY: 4 Bedroom
PROPOSED DESIGN FLOW (.1949): 480 gpd
LOCATION OF SITE: Lynn brook Acres Block B Lot 16
WATER SUPPLY: • Private • Public • X Well • Spring • Other _____
EVALUATION METHOD: • Auger Boring • X Pit • Cut

APPLICATION DATE _____
DATE EVALUATED: _____
PROPERTY SIZE: _____
PROPERTY RECORDED: _____
TYPE OF WASTEWATER: • X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 4%	0-3	Br scl wsbk	Fr ss sp	—	36"	common mica+ SAP PS	—	PS 0.3 - 0.4
		3-19	R C wsbk/MABK	F-Fr ss sp					
		19-36	R scl wsbk	Fr sss p					
		36-54	ver si/sap m	vFr ss sp					
2	LS 4%	0-5	Br scl wsbk	Fr sss p	—	52"	common SAP	—	PS 0.3+
		5-34	R C wsbk/MABK	F-Fr ss sp					
		34-52	R Y cl wsbk	Fr sss p					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	540 ft²	NA
System Type(s)	PPBPS	/
Site LTAR	0.3	/

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: MA & Assoc.
OTHER(S) PRESENT: _____

COMMENTS: _____