4638920089

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harvey Frueze DATE 2-28-79 PERMIT NO. 46

PHONE: Business _____ Home 536-7815

LOCATION 150 W TR on 1303 TR on 1479 TR on 1480 1 mi on Left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 18 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 3/4 ac


Character & Porosity of Soil Clay loam

Percolation Rate 60 min/in

Topography 10 % 5% to Store

Depth to Water Table 6' to 8'

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Wayne Orbison

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 2-28-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harvey Freeze DATE 10-26-78 PERMIT NO. 304

PHONE: Business _____ Home 536-7815

LOCATION 150 W TR on 1303 TR on 1479 TR on 1480 1 mi on Left S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 18 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	10 to 15% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6 to 8'	
			Rock or other impervious formations	None	

Lot Area 1 ac



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Put Stub out at ground Elev or above so system will not be too deep.

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold