COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____
ADDRESS: _____ APPLICANT: _____
PROPOSED FACILITY: _____ APPLICATION DATE: _____ DATE EVALUATED: 3-6-96
LOCATION OF SITE: Lot 19 Harbor Landing PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1950 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-24	sa lo rc/cL	fr sp-ss sp-sy p					PS @ 25-33"
		24-38	sa lo rbrn	c/cL fr sp sy p					
			Many y-brn	Mottles					
2	L ~10%	0-12	sa lo rbrn cL	fr					PS @ 25.3"
		12-38	wk sa lo R, r-brn c/cL	fr sp-ss p-sy p					
3	L ~40%	0-25	sa lo rc/cL	fr sp-ss p-sy p					PS 63
		25-44	wk sa lo rcL	fi ss p-sy p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____