DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Mike Kwon (New Lot 29) OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 3/13/95
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 25, Mills Road West
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____ EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LSS	0-4	gr-sl						.4
		4-20	sbk-c						+.35
		20-39	wk sbk-cl	some scattered gravels					-.3
		39-48+	wk sbk-cl						
			sl micaceous						
2		0-2	gr-l						.3
		2-7	sbk-c						
		7-28	wk sbk-cl						
		28-55+	wk sbk-cl w/						
			and sl stratified, very micaceous						
3		0-2	gr-l						.3
		2-26	sbk-c						
		26-52+	wk sbk-cl						
			sl-m micaceous						
4		0-4	gr-sl	vfr					.3
		4-16	sbk-c	fi					
		16-37	wk sbk-cl	mfi					
		37-48+	wk sbk-cl micaceous	fr					
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948):_____ SITE LONG-TERM ACCEPTANCE RATE:_____
EVALUATED BY:_____ OTHER(S) PRESENT:_____
COMMENTS:_____