IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mossett Clark DATE 10-27-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 North TL on 1300 2nd Rd East Church TR at end S. R. No. _____

SUBDIVISION NAME Jake Norman LOT NO. 175 SECTION OR BLOCK NO. 15


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Parent material Sandy Clay loam (Porosity good)
Percolation Rate Soil borings
Topography 2% slope
Depth to Water Table 6 to 8' to lake level
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 750
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 10-29-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold