IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Baxter DATE 10/31/88 PERMIT NO. 17 D

PHONE: Business _____ Home 664-7163 237 River Bend Rd

LOCATION 150 W TR PERTH RD TL Fern Hill TR
Riverbend (SR 1449) near end on L. S. R. No. _____

SUBDIVISION NAME CL and T LOT NO. 968 SECTION OR BLOCK NO. 15
3C-10-A-170 Fallstown


House ( ) future ✓ present Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey (silty at 30")
Percolation Rate 35 gpd/ft²
Topography ~15%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 1.06 Acre

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement Pump tank 1250



Plot of System NOT TO SCALE

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines 180' of 16"
Water Supply: Individual (✓) T and J
Public ( ) panels

Installed by AAA Enterprises (Sigmons)

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ARP

COMMENTS: Alarm and pump regulated 10/31/88
DRH cked system prior to [illegible]

CERTIFICATE OF COMPLETION BY André C. Price DATE 10/31/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold