## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr. Soper DATE 7-9-76 PERMIT NO.

PHONE: Business Home

LOCATION 1300 TR on 1449 TL on 2nd Rt at end. S. R. No.

SUBDIVISION NAME Jake Norman LOT NO. 183 SECTION OR BLOCK NO. 15

House ( ) Mobile Home (✓) Business ( ) Other


(Porosity Fair)

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Sand stone & sand
Percolation Rate soil borings
Topography 2% slopes on line
Depth to Water Table 10'+
Rock or other impervious formations Soft rock at 3'
+ depth soil on Top - System in soil.




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Will built 3 bedroom 2 bath house at later date. System will require good maintenance + reasonable water use.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-9-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold