64 M

3 35

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 133908 PIN# 4639035170 DATE 6-15-07

OWNER OR APPLICANT Spivey Construction Co PHONE: Business 704-663-4189 Home

ADDRESS PO Box 4268 Mooresville NC 28117

LOCATION Perth Rd N TL Fern Hill TR Bullfinch on right near end 270 Bullfinch Rd

SUBDIVISION Beacon Point BLOCK / SECTION 2 LOT 15 LOT AREA .77 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank: 1000 Gallons: STB 55 Date 6-27-07

Pump Tank: 1000 Gallons: PT 32 Date 6-24-07

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 840 Linear Feet 280

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 8

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* per plan specs

keep water line 10' from system or repair

Comments:/Conditions:

ST w/marker

Blue poly lok filter

INITIAL SITE SKETCH

See plan from Rollans Soil & Environmental Services

AS BUILT SKETCH

T+J panel installed as per ihitial site sketch 3/16" holesize

Tanks placed ~3' higher on slope than sketched

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Brad Shuler date 6/15/07 Installed by: G+M Enterprise Tony

Improvement Permit by: Judy McNeille date 6-15-07 Operation Permit by: Judy McNeille date 2-24-08

Authorization to Construct by: Judy McNeille date 6-15-07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK