CL+T
Section 18 lot 17

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System
Andrew C. Combs
221 Stillwater Road
Troutman, N.C.
28166

Date of Inspection
1-6-12

Permit Number
156232

County
Iredell

System Classification
LV-A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner
Same

Phone: (704) 873-2171

Phone:

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
NO Risers accessible need Risers over Septic Tank
S Signs of Infiltration
S Structurally Sound
S Landscape Position
NO Filter Cleaned

PUMP
YES Pump present and operating
37 Design GPM
37 Actual GPM
100 % Efficiency
S High water alarm operating properly
S Pipework in good condition
S Control panel in good condition
S Control floats operating properly
S Straps and float tree
S Effluent free and clear of solids

DRAIN FIELD
S No effluent surfacing
S Surface water diverted
S Line cover maintained properly
S Protected from traffic
S Distribution devices operating properly
S Repair area reserved

Date 1-6-12
LOW PRESSURE PIPE SYSTEM
S Turnups, cleanouts, valves located and protected
S Laterals free of excess solids
YES Laterals flushed
Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4	2'	2'

COMMENTS

Compliant ✓ Noncompliant ___
Signature J.C. Moore