IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Clary DATE 4-22-76 PERMIT NO. 94

PHONE: Business _____ Home 117-924-6448

LOCATION 503 Tl on 1300 2nd Rd Tl Pat Harris
1 end on Left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 164 SECTION OR BLOCK NO. 15

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Sandy Clay Loam Brown Coarse
Percolation Rate Nat Taken
Topography 3 to 4 % Slope
Depth to Water Table 10' +
Rock or other impervious formations None

Lot Area 1 acre

Lake 100'



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by Rowan Septic Tank

IMPROVEMENTS PERMIT BY J C Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 4-2-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold