IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David McCallum DATE 12-22-96 PERMIT NO 3737

PHONE: Business _____ Home 392-4477

LOCATION 1300 TR on 3rd St. East Church TR on 2nd Rd at end S. R. No 1522

SUBDIVISION NAME Lake Norman LOT NO. 144 SECTION OR BLOCK NO. 15

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area .175 acre


Character & Porosity of Soil Clay loam porosity Fair

Percolation Rate 5 min/inch

Topography Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 1 ft

Water Supply: Individual (✓)

Public ( )

Installed by Gladys Morris Septic Concord, NC

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 12-22-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold