IREDELL COUNTY HEALTH DEPARTMENT 4639107865

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bruce Cuckly DATE 6-14-95 PERMIT NO. 132

PHONE: Business _____ Home _____

LOCATION 1303 Flea 1500 FD on 21 to left of Plum

SUBDIVISION NAME Lake Norman LOT NO. 154 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 2 acres


Character & Porosity of Soil Clay loam

Percolation Rate 60 min. 1 in

Topography Slope

Depth to Water Table 48 in

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12 in

Water Supply: Individual (✓)

Public ( )

Installed by E. J. Evans

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Patricia Lewis Evans DATE 7-27-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold