Mooresville Office

✓4639121153

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Kilpatrick DATE 12-22-76 PERMIT NO. 326

PHONE: Business _____ Home _____

LOCATION 1300 Turn 2nd rd past church Turn 1st right at end S. R. No. _____

SUBDIVISION NAME CL+T/Lake Norman LOT NO. 192 SECTION OR BLOCK NO. 15

Site Address: 140 Venus Lane - Stol.

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Soil Survey Type

Topography Level

Depth to Water Table 12" stone

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Gladius Morrison Cornelius, N.C.

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 2-22-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold