N4:30

07584

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John F. Eisele DATE Nov. 4 '87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 N. TR 1300 (Fernhill Rd.) TR 1449 (Riverbend) TR 1st dirt street Bear left near end on Rt. S. R. No. _____

SUBDIVISION NAME CL&T Lake Norman LOT NO. 959 SECTION OR BLOCK NO. _____

DW.

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay

Percolation Rate 2, 4

Topography ~25%


Depth to Water Table 4'+

Rock or other impervious formations scattered rock numerous

Lot Area .8 Ac.

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: John Eisele

IMPROVEMENTS PERMIT BY David L. Hanson RS.

COMMENTS: Pressure dose conventional field by using a ball valve at the head of each ditch and a 1½ pipe down the center of each ditch with 1 5/32" hole drilled every 5 feet (2 pressure heads) Must follow contour, Install drainfield on lay no less than 30" to bottom of ditch.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold