IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John + Marguerite Taylor DATE 4-23-80 PERMIT NO. 98

PHONE: Business _____ Home _____

LOCATION 150W TR 1303 TL 1300 TR 1400 TR 1432 ON ~.2 mile on left

SUBDIVISION NAME Lake Norman S. R. No. _____ LOT NO. 28 SECTION OR BLOCK NO. 16


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(X)	No	( )
Auto. Dishwasher	Yes	(X)	No	( )
Auto. Wash. Machine	Yes	(X)	No	( )
Site Suitable	Yes	(X)	No	( )

Lot Area 1 acre +

Character & Porosity of Soil Sandy clay loam
Percolation Rate Rapid
Topography Hilly
Depth to Water Table 6'+
Rock or other impervious formations None observed



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by Richard Abernathy

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-23-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold