4639154485

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L. J. Thomas DATE 8-21-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 13031 TR on 1300 TR on 1400 TR on 1432 S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 32 SECTION OR BLOCK NO. 16

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Sandy, Gravel Material


Percolation Rate 60 min/in

Topography 10% Slope

Depth to Water Table 6' to 8'

Rock or other impervious formations None

Lot Area 3 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Dellinger Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 8-21-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold