4639 15 5556

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John A. Walker DATE 9-21-78 PERMIT NO. 230

PHONE: Business _____ Home _____

LOCATION 150 w TR on 1303 TL on 1300 TR on 1400 TR on 1432 Marietta Rd Fern Hill S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 33 SECTION OR BLOCK NO. ~~15~~ 16


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms #1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3 ac. +

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate 60 min/in
Topography 10 to 15 % Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Larry Tucker

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 9-21-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold