## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rob Miller DATE 6-20-22 PERMIT NO. 130

PHONE: Business _____ Home 872-3223

LOCATION 1303 Turn 1300 TR on 1st Rd Lot 6 on Church Rd on Left To Right Turn TR S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 24 SECTION OR BLOCK NO. 6


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes | ( ) | No | (✓) |
| Auto. Dishwasher | Yes | (✓) | No | ( ) |
| Auto. Wash. Machine | Yes | (✓) | No | ( ) |
| Site Suitable | Yes | (✓) | No | ( ) |

Character & Porosity of Soil Sandy Clay loam
Percolation Rate 30 min/in
Topography Slope
Depth to Water Table 6-10'
Rock or other impervious formations None

Lot Area 3 Acre




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )

Installed by Hale Hawkins

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hawkins DATE 6-20-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold