IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clarence Rogers DATE 9-8-76 PERMIT NO _____

PHONE: Business _____ Home _____

LOCATION Lum on Perth Rd at Troutman. T.R. on 1321 - Tk. on 1462 Trailer on Right near Point S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 47 SECTION OR BLOCK NO 18

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Lake	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low	
			Rock or other impervious formations	None	

Lot Area 20,000 Sq ft



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 260
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Osteloff

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. O. Stutesman DATE 9-8-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold