IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE Nov. 8, 05

PERMIT# 13/904 PIN# 4639 20 2237

OWNER OR APPLICANT ~~Nathan Lyall Homes LLC~~ SHANE & KATIE LONNEMAN PHONE: Business 330 832 4091 Home

ADDRESS 4330 Steeplite St. SE, Massillon, OH 44646

LOCATION 150W TR Perth Rd (N) TL FERN Hill on Right at lot w/ Periwinkle

SUBDIVISION Lakewood Crossing BLOCK / SECTION LOT 13 LOT AREA .97ac SITE CLASS. IS DESIGN FLOW 480gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 760 Date 5-11-13

Pump Tank: 1000 Gallons; PT 363 Date 7-27-13

Pump Make: Myers Model ME45MC Serial No. 27632A000

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 6@80' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM 25% Reduction

Repair System Description: LP PMPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Initial site evaluation and system design performed by Rollins Soil & Env Services

Comments:/Conditions: ST & PT checked 10-4-13

Lines Checked 10-11-13 Quick 4

PM Connections Checked 10-11-13

12/6/13 2ft pressure set, electrical alarm Checked

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

The proposed / existing Deck / Addition addition does not appear to impact the existing septic system.

**NOTE: Must keep Footers at least 5ft from Septic

Must keep Access to ST for Maint.

Maina Dotson R.S.

Date: 5/29/14

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒

Signed: Wesley Edwards date 11-10-05

Improvement Permit by: date 11-8-05

date 4-1-13

Installed by: Specialty Septic RS date 12/6/13

Operation Permit by: Maina Dotson date

Existing System Inspection by: date

OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK