IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13923 PIN# 4639204948 DATE Nov. 8 05

OWNER OR APPLICANT Nations Land Co, LLC PHONE: Business 330-832-4091 Home

ADDRESS 4330 Steinlite St SE + Massillon OH 44646

LOCATION 150 in TR Fourth Rd. (N) TL FERN Hill on right before get w/ Bagby

SUBDIVISION Lakewood Crossing BLOCK / SECTION LOT 20 LOT AREA .90Ac SITE CLASS. 4/5 DESIGN FLOW 440gpd L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 1000 Date 11/11/05

Pump Tank: 1000 Gallons: PT 17 Date 2/8/06

Pump Make: Goulds Model WE03511M Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: PM 25% Reduction

Repair System Description: LPPPBS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Physical site evaluation and system design performed by Rollins Soil & Env. Services

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Tilley Edwards date 11-10-05

Improvement Permit by: date 11-8-05

Authorization to Construct by: RS date 1/5/06

Installed by: C+S

Operation Permit by: RS date 9/28/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK