11:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 131933 PIN# 4639214241 DATE Nov 10, 05

OWNER OR APPLICANT Nations Land Co. LLC / Mark Builders PHONE: Business _____ Home _____

ADDRESS 4330 Steubite St. SE / Massillon, OH 44646

LOCATION 150 W TR Perth Rd (N) TL Fern Hill TR Harvest Lane 1st Lot on Right

SUBDIVISION Lakewood Crossing BLOCK / SECTION _____ LOT 24 LOT AREA .69Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .03

Septic Tank: 1000 Gallons: STB 825 Date 9-15-08

Pump Tank: 1000 Gallons: PT 302 Date 6-10-08

Pump Make: ZOELLER Model N152 Serial No. .4HP

Nitrification Field: No Fields 1 Square Feet 570+ Linear Feet ~~X~~ 285

No Lines 3 (2CF) Trench Width ~~X~~ Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☒ Basement wo/plumbing

Comments:/Conditions: SEE Plan Specs

Critical site evaluation and system design performed by Rollins Soil and Env. Services

Comments:/Conditions: PRELIM

2/22/08 Reviewed Floor plans, essentially in Compliance with original plan

★ Must place house as shown in original plan.

INITIAL SITE SKETCH

★★ Use "In line" filter in PT

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Keep house NO more than 35FT off back Property line

Tanks moved out of house box

Tanks, lines, pressure & elect. Checked 12/31/2010 by BA

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 11-14-05 Installed by: ROWAN RETS

Improvement Permit by: _____ date 11-10-05 Operation Permit by: _____ date 10/14/2010

Authorization to Construct by: _____ date RS 2/22/08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK