DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt. Partners APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-7-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4 Bdrm PROPERTY SIZE: _____
LOCATION OF SITE: lot 21 phase 4 Beacon Pt PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-12	gr Rmsl	frss sp					.3
		12-38	mstsk RC	frssb					
		38-48	mstsk gycl	frssb					
2		0-7	wkSbk Rmsl	frssp					.25
		7-43	wkmbk RC	frfi wSBD					
		43-55	wkSbk gycl	frssp					
3	5%	0-5	gr frmsl	frssp					.25 = 3
		5-36	mstsk RC	frfi wSBD					
		36-55	mstsk gycl	frssp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	25	25
System Type(s)	LPP/CS	CP/CS
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): ES
EVALUATED BY: _____
OTHER(S) PRESENT: David Flemmings