DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt Partners APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-12-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 420gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 22 Beacon Pt phase 4 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut ~~NEED AH towards pl 4 23~~
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-9	gr-gr ksbk han-rdgn sl/scl	frssso					.3
		9-30	m BBk RC/L	fr ss-sss					
		30-56	wk fsbk yr L	fr sss common mic/sap					
2	2% ±	0-14	m/sbk RC	fr sss so/p					.3
		14-35	m/sbk RCL	fr sss/p					
		35-47	(BC) wk fsbk scl	fr ss/p common mic/sap					
3	2% ±	0-36	sbk RC	fr ss so/p					.3
		36-46	wk fsbk yr cl	fr sss/p common mic/sap					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CRAW 25% Red	Comp pumped 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DHoffman
OTHER(S) PRESENT: Paul Pennington

N36°25'33"E
287.73
N39°34'19"E
276.52
N40°44'05"E
316.09
22
21
20
DRIVE
LC
2400
1400
4400
3400
PC= 0+87.58
PT
2+89.68