DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt Partners APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-20-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4 bdrm PROPERTY SIZE: _____
LOCATION OF SITE: lot 16 Block 4 Beacon Pt PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	17% L	0-3	gr brwSL	frssSP					e2 .3
		3-24	BK wk fk mass RC	fi SP, SBK					
		24-49	massive dk brn SL SAP	fr ss SP	few mott in fractures				
2		0-10	gr, brwSL	fr SSSP					.25
		10-92	m BK RC-d	fr SSSP	fair/brn mottles	12-88"			
3		0-98	wk mbk sbk	fr ss SP	Common brn mottles Common dist SAP				.25
4		0-3	Brw SL	gr fr SS, SP					PS .3+
		3-17	Rd Brw C/CL	m-w SBK SS, SP SE Fr					
		17-24	Rd Brw C L w/few to many SAP Inclus	SS, SP, SE FR, SE					
		24-72	SL/L SAP	massive fr SS, SP, SE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPPBPS	LPPPBPS
Site LTAR	.125	.125

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DMF
OTHER(S) PRESENT: Rick Kennedy
Very gullied/complex topo over most of site.