DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt Partners APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5 Nov 04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: lot 8 of Beacon Pt PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	17%	0-5	gr brnsdl	frssso	few mod sep 25"+				.3
		5-30	mfsbk RC	fr-frssp sspo					
		30-50	mottled sl sapo	frssp					
2		0-6	gr brnsdl	frssso					.3
		6-21	mfsbk RC	fr sp sspo					
		21-31	mfsbk yred	fr slsp-sspo mod sep					
		31-52	mottled sl sapo	frssp					
3		0-5	gr brnsdl	frssso					.3
		5-32	mfsbk RC	fr sspo					
		32-42	wkfsbk yr cl	frssso / common mod sep					
		42-53	mottled yr-dkbrn sl sapo frssp dry						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	15	15
System Type(s)	LPP&BS	LPP&BS
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): 15
EVALUATED BY: [illegible]
OTHER(S) PRESENT: Paul Pennington