DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt. Partners — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 5-6-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 4/Bdrm — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 4 of Sub of Beacon Pt — PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-19	wk f gr sa bk brn sl	fri ss sp	few common m sol sap				.3
		19-52	massive y-g brn sl/sap	fri ss sp					
2		0-3	gr brn sl	fri ss sp					.3
		3-17	(B-C) wk m sbk rc/cl	fri sp ss sp sap	brn/gry m sol sap				
		17-52	massive sl/l sap	fri ss sp					
3	14% L	0-11	gr brn sl	fri ss sp					.3
		11-28	m sbk rcl	fri ss sp sap					
		28-40	wk f sbk ry sl	fri ss sp	gry/brn m sol sap				
		40-52	massive ry sl sap	fri ss sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	Conv 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DWH
OTHER(S) PRESENT: Mark Rosenzweig


S32°06'34"E
680.21
S19°57'20"E
402.76
4
3
6'
5'
LC
5+00
6+00
4+00
PT
PC