DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Beacon Pt Partners APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-9-24
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 11 Phase 4 Beacon Pt. PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% L	0-8	gr bnSL	frSSsp					.3
		8-12	wkmod fsbk RC	frSSsp					
		12-27	(RC) wkfsbk mod	frSSsp	few mbsp				
		27-49	massive rgySLsp	frSSsp	few mbsp, few mtbl				
2		0-18	wkmfsbk RC	frSSsp	few mbsp, few mtbl				.3
		18-34	(RC) wkfsbk mod RC	frSSsp	common mbsp				
		34-51	massive slsp	frSSsp	few mbsp				
3	8% L	0-9	gr bnSL	frSSSp					.25
		9-25	mfsbk RC	frSSSp					
		25-47	(RC) wkfsbk RC	frSSSp	few pores mottles few mbsp				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CRP(25%Red)	CPPPBPS
Site LTAR	.25	.125

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): LS
EVALUATED BY: _____
CERTIFIED REPRESENTATIVE: _____