)IVISION OF ENVIRONMENTAL HEALTH
)N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

)WNER: Crescent Resources APPLICANT: _____
)DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/3/99
'ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
.OCATION OF SITE: Beacon Pt II Lot #9 PROPERTY RECORDED: _____
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Pit 1	0-5	SCL						PS .30 30"
		5-30	Rd CL m-FSBK FR SS SP						
		30+	Unsuitable	Rock w/ SAP Indus					
			(Soil depth Varies From 28-46")						
2	Pit 2	0-18	Rd CL m-FSBK FR SS SP						PS .3
		18-51"	Yel/Rd m-w SBK FR SS, SP w/ few Indus or SAP						
3		0-7	Brn SCL GR FR						PS .3
		7-99	Rd/Brn CL m-m SBK SS, SP, SE, FR						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____