7187

IREDELL COUNTY HEALTH DEPARTMENT

II

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E. Wesley & Kimberly T. Burnett DATE 8-14-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 N. TL 1300 (Fern Hill) TR 1432 (Marietta) ~ ½ mile on Rt S. R. No. _____

SUBDIVISION NAME CL&T Lake Norman LOT NO. 937 SECTION OR BLOCK NO. 16


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2, 4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	15-25%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	44
			Rock or other impervious formations	none obs.

Lot Area 20000 ft²+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by J R Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP, DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D R Hinson RS DATE 8-14-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold